



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 10
WASHINGTON OPERATIONS OFFICE
300 Desmond Drive SE, Suite 102
Lacey, Washington 98503

August 28, 2007

FILE COPY

Susie Abrahamson
SPOKO Fuels – West Plains
14212 W State Route 2
Medical Lake, WA 99022

Re: Underground Storage Tank Inspection of SPOKO Fuels – West Plains, located at 14212 W St Rt 2, Medical Lake, Washington, EPA Facility ID No. 4190012 – Spokane Indian Reservation.

Dear Ms. Abrahamson:

This letter is in regard to the underground storage tank (UST) inspection that I conducted at your facility, SPOKO Fuel – West Plains, on August 1, 2007. At the time of this inspection, I found that your facility was in compliance with federal UST regulations as stated in Chapter 40, Code of Federal Regulations, Part 280, Technical Standards and Corrective Action Requirements for Owners and Operators of USTs. We recognize and appreciate the steps you and your brother have taken to achieve and maintain compliance with federal UST regulations.

As a reminder print and save monthly line (piping) release detection report results from your Veeder-Root tank monitor. You will need to check with your service provider to get this report.

If you have any technical or regulatory questions in the future, please feel free to either call me at (360) 753-8072 or 1-800-424-4372, extension 8072, or send me an e-mail at greeves.jim@epa.gov.

Sincerely,


Jim Greeves
UST Inspector

cc: Holly LeBret, Executive Assistant, Wellpinit, WA
Rudy Peone, Director of Natural Resources, Wellpinit, WA